

Element G	Building Sitework
Sitework Improvements	G2010 Roadways

PART 1 - GENERAL

1.01 OVERVIEW

- A. This Section includes concrete roadway, as applicable to the Project.

PART 2 - DESIGN CRITERIA

2.01 GENERAL

- A. Roadway pavement will be minimum 9-inch thick reinforced portland cement concrete in accordance with TxDOT Item 360, placed over minimum 8 inch lime-fly ash stabilized subgrade.
- B. New roadway work will consist of access to public entrance and dock/loading areas.
- C. Pavement and subgrade preparation must be consistent with recommendations in the geotechnical investigation report prepared for the Project.
- D. Provide a concrete sealer at drop-off points and dock areas.

Element G	Building Sitework
Sitework Improvements	G2010 Roadways

PART 3 - DOCUMENT REVISION HISTORY

Issue	Date	Revision Description	Reviser
	20190301	Original Issuance	
Rev. 1			
Rev. 2			
Rev. 3			
Rev. 4			
Rev. 5			

END OF ELEMENT G2010