
PART 1 - GENERAL

1.01 OVERVIEW

- A. This Section includes sidewalks, steps/platforms, and ramps.

PART 2 - DESIGN CRITERIA

2.01 GENERAL

- A. Construct at-grade sidewalks of reinforced, minimum 3,000 psi normal weight concrete, with a minimum 4-1/2 inch thickness, over 6 inches of compacted subgrade. Provide a light broom finish.
- B. Pavement and subgrade preparation must be consistent with recommendations in the geotechnical investigation report prepared for the Project.
- C. Avoid heavily textured or raised pattern finishes where patients in wheelchairs and with IV poles will be present.
- D. Provide low profile identifying markers at top edge of sidewalks at locations where below grade irrigation sleeves are present.

PART 3 - SPECIAL CONTRACT DOCUMENT REQUIREMENTS

3.01 GENERAL

- A. Where required by Code, building exits and entries shall be provided with TAS and ADA compliant pedestrian paving and ramps. Provide detectable warnings in accordance with TAS and ADA requirements at curb ramps, and where walks and adjoining vehicular ways are not separated by a curb, railing, or other element.

Element G

Site Improvements

Building Sitework

G2030 Pedestrian Paving

PART 4 - DOCUMENT REVISION HISTORY

Issue	Date	Revision Description	Reviser
	20190301	Original Issuance	
Rev. 1			
Rev. 2			
Rev. 3			
Rev. 4			
Rev. 5			

END OF ELEMENT G2030